



# Engineering School Bejar

---

Alexandra Troi, EURAC research  
José L. Hernández and Miguel A. García, CARTIF

---

The research leading to these results has received funding from the European Community's Seventh Framework Programme (FP7/2007-2013) under grant agreement n° 260162



This document reflects only the author's views. The European Union is not liable for any use that may be made of the information contained therein.



## Case Study 7 Engineering School of Béjar Salamanca - Spain



Béjar (Salamanca), 30/10/2012

3ENCULT CS7. Engineering School of Béjar

# Local Case Study Team



## CARTIF Technology Centre

Cartif is a horizontal center which covers a wide range of scientific disciplines. This characteristic, which makes us stand out from other technology centres of a more vertical or specialised nature, enables us to provide companies with integral solutions. Today, Cartif has a staff of 200 researchers, revenue exceeding €10 million and a client portfolio comprising 120 enterprises and institutions. The centre has facilities of 16,500 m<sup>2</sup> (distributed in three buildings).

## G1S – Soliker

SOLIKER design and manufacturers Solar Thermal Collectors, Thin Film photovoltaic modules and laminated photovoltaic glass for architectural envelopes under the ISO 9001 quality standards at its production plant located in Béjar (Salamanca- Spain), which has more than 18000 m<sup>2</sup> of net industrial surface.

## University of Salamanca

The University of Salamanca, founded in 1218, is a medium sized university with over thirty thousand students. It is the second most popular university in the country for students wanting to study outside their home districts.

# The historical features and architectural aspects



Built in 1968

Architect: Manuel Blanc Díaz

- Engineering School founded in 1852
- Current building built in 1968
- Built in concrete and large glazed areas
- Number of floors: 7
- Orientation: West-East

- 1- Influenced by the Constructivist Architecture
- 2- Breaks with traditional architecture in the zone
- 3- Takes into account climatic conditions (i.e. lattice)
- 4- First building of the University of Salamanca in the village
- 5- Influence of textile industry



# The historical features and architectural aspects



*...the esthetical solution of the building is based in its own function and the environmental and climatic conditions...*

*...we may say that the dignity the School requires has been achieved considering its simplicity in the composition and treatment...*

Manuel Blanc Díaz

School of Engineers in Béjar project report



# The historical features and architectural aspects




<b>Location</b>	Béjar (Salamanca)	<b>Altitude</b>	959 m.a.s.l.
<b>Project year</b>	1962	<b>Construction year</b>	1968-1972
<b>Use</b>	Industrial Engineering High Technical School in Béjar		
<b>Stylistic value</b>	This building influenced by the Constructivist Architecture, which flourished in the Soviet Union, achieves a rupture with the traditional architecture of the site, carried out under industrial design criteria, without adornment, and with a huge geometrical and functional principles, reinterpreting some characteristics of the local construction, influenced by climate conditions, as big lattices for protecting from winds and rain.		
<b>Cultural and historic value</b>	It is the first building that the University of Salamanca builds in this village. Its construction meant a big academic activity growth in the area, and a big support to the textile industry, which had a long tradition in the region.		
<b>Conservation state</b>	Its conservation state is well, although it has some pathologies in the jutting outs due to the humidity. There were made two interventions. In both the roof was changed, replacing all the external windows in the second refurbishment, using ones with thermal bridge rupture and isolating glass.		

# The historical features and architectural aspects



<b>Structure</b>	Reinforced concrete pillars and grid slabs. Foundations were made with piles of 60 cm diameter and between 6 and 12 meters in deep with pile cap and perimeter walls made in reinforced concrete.		
<b>Envelopment</b>	Concrete bricks with air chamber and interior layer in double-hollow brick in most of façade elements. Roof is made in zinc plate above brick light partitions. Metallic windows with thermal bridge rupture and double glass 4/20/4 which were integrated in the last refurbishment.		
<b>Floors</b>	5 floors in access level (west façade) and 2 semi-basement floors (exterior in east façade)		
<b>Built area</b>	13.624,85 m <sup>2</sup>	<b>Heating system</b>	Gas boilers and radiators
<b>Net usable area</b>	9.467,10 m <sup>2</sup>	<b>Heating days / HDD</b>	240 days / 1804,45 HDD
<b>Heated area</b>	9.467,10 m <sup>2</sup>	<b>Cooling systems</b>	Fan-coils in library
<b>Heated volume</b>	33.150 m <sup>3</sup>	<b>Average power consumption</b>	230.000 kWh/year
<b>Cooled area</b>	150 m <sup>2</sup>	<b>Average heating consumption</b>	60.000 liters/year

# The historical features and architectural aspects



# The historical features and architectural aspects



4º P	DIBUJO	O. TECNICA	LABORATORIOS
3º P	AULAS	DELEGACIONES	LABORATORIOS
2º P	AULAS	BIBLIOTECA	LABORATORIOS
1º P	AULAS	DIRECCION	LABORATORIOS
P BAJA	AULA MAGNA	ADMINISTRACION	LABORATORIOS
SEMIS. 1º	COMEDOR	CLINICA	TALLERES
SEMIS. 2º	SERVICIOS		

# The historical features and architectural aspects




Traditional architecture elements reinterpretation.





# The historical features and architectural aspects



Traditional architecture elements reinterpretation:  
- Climate conditions protection (wind and rain)



# The historical features and architectural aspects



# The historical features and architectural aspects



# The historical features and architectural aspects



# The historical features and architectural aspects

**3encult**  
EFFICIENT ENERGY FOR EU CULTURAL HERITAGE



# The historical features and architectural aspects

**3encult**  
EFFICIENT ENERGY FOR EU CULTURAL HERITAGE



# The historical features and architectural aspects

**3encult**  
EFFICIENT ENERGY FOR EU CULTURAL HERITAGE



# Problems, diagnosis and interventions



## Main problems identified

- Overheating in summer, mainly in east façade.
- Heating system: only two distribution systems for the whole building, so there are very different temperatures and discomfort problems derived.
- Cooling system: manual control strategy of library's cooling system, so appears discomfort problems.
- Oversized lighting system on corridors and hall.
- Lighting circuits incorrectly distributed on classrooms.
- Daylight and solar radiation underutilized.
- High air tightness level on external windows and doors.


# Problems, diagnosis and interventions



## Diagnosis

- Energy performance simulation by using the PHPP tool to compare with other tools and real data (both historical and real-time monitored).
- RES integration viability study.
- Analysis of thermal bridges by using infrared thermography system.
- Blower door test in order to analyse the air tightness on external windows.
- Local studies regarding energy efficient solutions as in lighting system, etc.

# Diagnosis: Methodology




# Diagnosis

## 1. Infrared thermography



First IR report approach

Planned to develop a second IR thermography report



# Diagnosis


## 1. Infrared thermography



# Diagnosis



## 2. Blower door test



1. Physics laboratory
2. Library

# Diagnosis


## 2. Blower door test

Room	Floor area (m <sup>2</sup> )	Height (m)	Furnitures (m <sup>2</sup> )	Volume (m <sup>3</sup> )	Envelopment area (m <sup>2</sup> )
Laboratory	171,78	3,30	-	566,87	520,97
Library	97,36	3,51	-	341,73	361,66

Beaufort number	Name	Wind speed (m/s)	Description
3	soft breeze	3,6-5,4	Small leaves and twigs in constant motion, the wind displays a light flag

## Initial conditions

- Physics Laboratory
  - Outdoor temperature = 3°C
  - Indoor temperature = 19,1°C
  - Indoor RH = 34,2%
- Library
  - Outdoor temperature = 5°C
  - Indoor temperature = 20,3°C
  - Indoor RH = 38,4%



# Diagnosis



## 2. Blower door test

### TEST 1 - LABORATORY

**Test BlowerDoor**  
EN 13829  
Minneapolis BlowerDoor Model 4 - Testite Express 3.6.7.0


Edificio objeto:	ET61 Bajar	Técnico:	A. Molas	
Baja:		Fecha:	02/07/2013	
<b>Temperatura y Viento</b>				
Temperatura interior:	18 °C	Fuerza del viento:	3	
Temperatura exterior:	3 °C	Puntos exteriores de referencia de medición:	1	
Presión barométrica: Nominal:	90485 Pa	Exposición al viento del edificio:	C	
Incertidumbre a causa del viento (Tabla de Gertler): 11 %				
<b>Elementos de medida</b>				
Diáfragma	Edificios Presión	Ventilador Presión	Flujo del ventilador $V_r$	Tolerancia
DA000	0	0	0	0
ABr1	-3.2	85	6436	0.37
0	-74	85	6098	-0.50
0	-68	76	5990	-0.80
0	-64	71	5690	0.15
0	-59	68	5416	0.37
0	-54	63	5093	0.12
0	-48	53	4946	0.60
0	-38	40	4465	0.01
0	-33	35	4181	0.35
0	-29	28	3781	-0.66
ABr2	+1.7	—	—	—
Coeficiente de correlación:		1.000	Intervalo de confianza:	
$C_{\text{cor}}$ [ $\text{m}^2/\text{Pa}^2$ ]		705	min. 738	max. 674
$C_L$ [ $\text{m}^2/\text{Pa}^2$ ]		687	min. 710	max. 667
$n$ [ ]		0.92	min. 0.83	max. 0.99

**Resultados**

	$V =$	$967 \text{ m}^3$	$A_c =$	$172 \text{ m}^2$	$A_e =$	$821 \text{ m}^2$		
	$V_{50}$	Incertidumbre	$R_{50}$	Incertidumbre	$W_{50}$	Incertidumbre	$q_{50}$	Incertidumbre
	5191	± 12 %	0.3	± 15 %	30.2	± 13 %	10.0	± 13 %
Despresurización								

### RESULTS

Air flow rate (m<sup>3</sup>/h) resulting from the Blower Door Test



# Diagnosis



## 2. Blower door test

### TEST 1 - LABORATORY

Test BlowerDoor EN 13829								
Edificio objeto: ET61 Bajar Bajar			Técnico: A. Molas Fecha: 02/07/2013					
Temperatura y Viento								
Temperatura interior:	18 °C	Fuerza del viento:	3					
Temperatura exterior:	3 °C	Puertas exteriores de referencia de medición:	1					
Presión barométrica: Nominal:	904,6 Pa	Exposición al viento del edificio:	C					
Incertidumbre a causa del viento (Tabla de Delft): 11 %								
Elementos de medida								
Diáfragma	Bártulos Presión	Ventilador Presión	Flujo del ventilador Vr	Tolerancia				
DAB001	0	0	0	-0,1				
ΔB01	-3,2	—	—	—				
0	-74	65	6436	0,37				
0	-68	76	6098	-0,50				
0	-64	71	5990	-0,80				
0	-59	66	5690	0,15				
0	-54	63	5416	0,37				
0	-48	53	5093	0,12				
0	-44	48	4946	0,60				
0	-38	40	4465	0,01				
0	-33	35	4181	0,35				
0	-29	38	3781	-0,66				
ΔB02	+1,7	—	—	—				
Coeficiente de correlación:		1,000	Intervalo de confianza:					
$C_{\text{cor}}$	[m³/h Pa⁻¹]	705	min. 738	max. 874				
$C_L$	[m³/h Pa⁻¹]	687	min. 710	max. 857				
n	[ ]	0,62	min. 0,53	max. 0,66				
Resultados								
	V =	967 m³	A <sub>v</sub> =	172 m²	A <sub>c</sub> = 821 m²			
	V <sub>50</sub>	Incertidumbre	R <sub>50</sub>	Incertidumbre	W <sub>50</sub>	Incertidumbre	q <sub>50</sub>	Incertidumbre
Despresurización	5191	± 12 %	8,3	± 15 %	30,3	± 13 %	10,0	± 13 %

### RESULTS

#### Laboratory test 1 (with opened ventilation chimneys)

- $V_{50}$  Average flow at 50 Pa (m³/h) = 5191 m³/h
- $n_{50}$  Airchange rate at 50 Pa (1/h) = 9,2 h⁻¹
- $w_{50}$  Air flow at 50 Pa / usable floor area = 30,2 m³/m²·h
- $q_{50}$  Air flow at 50 Pa / envelopment area = 10,0 m³/m²·h
- Annual average airchange rate = 9,2/20 = 0,46 h⁻¹

#### Laboratory test 2 (with closed ventilation chimneys)

- $V_{50}$  Average flow at 50 Pa (m³/h) = 4778 m³/h
- $n_{50}$  Airchange rate at 50 Pa (1/h) = 8,4 h⁻¹
- $w_{50}$  Air flow at 50 Pa / usable floor area = 27,8 m³/m²·h
- $q_{50}$  Air flow at 50 Pa / envelopment area = 9,2 m³/m²·h
- Annual average airchange rate = 8,4/20 = 0,42 h⁻¹

# Diagnosis



## 3. Monitoring system

Monitored areas:

- Library and offices
- Boilers room
- Physics laboratory and corridor
- Roof (climatic conditions)



# Diagnosis




## 3. Monitoring system

Thermal energy consumption	Thermal demand (kWh)	Comfort conditions	Indoor relative humidity (%)
	Water inlet and outlet temperature (°C)		Indoor temperature (°C)
	Pressure (bar)		Occupancy (binary)
Lighting system	Indoor iluminance (lux)	Climatic conditions	Available temperature (°C)
	Lighting actuators state (binary)		Windows opening (binary)
	Occupancy (binary)		Heating system state (binary & %)
Electric energy consumption	Voltage (V)	Climatic conditions	Outdoor temperature (°C)
	Intensity (A)		Outdoor irradiance (lux)
	Real power (W)		Sunset (lux)
	Reactive power (VAr)		Rain sensor (binary)
	Power factor (value)		Wind direction (degrees)
	Armonics distortion (value)		Wind speed (m/s)
	Real energy (Wh)		Direct solar radiance (W/m <sup>2</sup> )
	Reactive energy (VAhr)		Outdoor relative humidity (%)
			Pluviometer (l/h)

# Diagnosis

## 3. Monitoring system

Monitoring System before refurbishment - List of Sensors & Meters installed in the Boilers' Room



(1) - Inlet Water Temperature Sensor

(2) - Outlet Water Temperature Sensor  
Circuit 1

(3) - Outlet Water Temperature Sensor  
Circuit 2

(4) - Pressure Sensor - After Water Pump  
Circuit 2

(5) - Pressure Sensor - After Water Pump  
Circuit 1


(6) - Pressure Sensor - Before Water Pump  
Circuit 2

(7) - Pressure Sensor - Before Water Pump  
Circuit 1

# Diagnosis

## 3. Monitoring system

Monitoring System before refurbishment - List of Sensors & Meters installed in the Library and Offices.




Plan of the Library & Offices

- (1) Occupancy Sensor 120°
- (2) Occupancy Sensor 360°
- (3) Occupancy Sensor 360°
- (4) Occupancy Sensor 120°
- (5) Comfort & Occupancy Multisensor
  - a) Occupancy Sensor 360°
  - b) Indoor Temperature (°C)
  - c) Indoor Brightness (lux)
- (6) Comfort & Occupancy Multisensor
  - a) Occupancy Sensor 360°
  - b) Indoor Temperature (°C)
  - c) Indoor Brightness (lux)
- (7) Electrical Consumption - Fancoil North Library
- (8) Electrical Consumption - Fancoil Center Library
- (9) Electrical Consumption - Fancoil South Library
- (10) Electrical Consumption - Fancoil Office II
- (11) Electrical Consumption - Fancoil Office I
- (12) Comfort - Temperature Sensor (°C)
- (13) Comfort - Indoor Brightness (lux)
- (14) Comfort Multisensor
  - a) Indoor Temperature (°C)
  - b) Indoor Relative Humidity (%)
- (15) Comfort - CO2 Level
- (16) Comfort - Indoor Brightness (lux)
- (17) Comfort - Indoor Temperature (°C)

# Diagnosis

## 3. Monitoring system

Monitoring System before refurbishment - List of Sensors & Meteris installed in the Physics Laboratory




Plan of the Physics' Laboratory

- (1) Occupancy Sensor 120°
- (2) Occupancy Sensor 120°
- (3) Occupancy Sensor 120°
- (4) Occupancy Sensor 120°
- (5) Occupancy Sensor 360°
- (6) Occupancy Sensor 360°
- (7) Occupancy Sensor 360°
- (8) Occupancy Sensor 360°
- (9) Comfort & Occupancy Multisensor
  - a) Occupancy Sensor 360°
  - b) Indoor Temperature (°C)
  - c) Indoor Brightness (lux)
- (10) Comfort & Occupancy Multisensor
  - a) Occupancy Sensor 360°
  - b) Indoor Temperature (°C)
  - c) Indoor Brightness (lux)
- (11) Comfort & Occupancy Multisensor
  - a) Occupancy Sensor 360°
  - b) Indoor Temperature (°C)
  - c) Indoor Brightness (lux)
- (12) Comfort & Occupancy Multisensor
  - a) Occupancy Sensor 360°
  - b) Indoor Temperature (°C)
  - c) Indoor Brightness (lux)
- (13) Comfort Multisensor
  - a) Indoor Temperature (°C)
  - b) Indoor Relative Humidity (%)
- (14) Comfort - Temperature Sensor (°C)
- (15) Comfort - Indoor Brightness (lux)
- (16) Comfort - CO2 Level
- (17) Comfort - Indoor Temperature (°C)
- (18) Comfort - Indoor Brightness (lux)

# Diagnosis

## 3. Monitoring system





The screenshot shows a web-based interface for the Building Management System. At the top, there's a header with the 3encult logo and the text "Building Management System". Below the header, there are two buttons: "Download data" and "Update values". The main content area is titled "CS7 - Béjar" and displays data for a "Honeywell XFL821AJ1 (2B)" device. The data is presented in a table with four rows:

CS7_2Bas_Temp010V_GenIn_28	Timestamp	CS7_2Bas_Temp010V_OutC2_28	Timestamp
35.545% of full level	2012.10.29 at 11:55:00 AM	33.380% of full level	2012.10.29 at 11:55:00 AM
CS7_2Bas_TempPtk_OutC1_28	Timestamp	CS7_2Bas_Press_AfterC1_28	Timestamp
40.67degrees C	2012.10.29 at 11:55:00 AM	49.205% of full level	2012.10.29 at 11:55:00 AM

# Diagnosis

## 4. Building energy performance simulation (PHPP)



Specific building demands with reference to the treated floor area

use: Monthly method

	Treated floor area 10525,5 m <sup>2</sup>	Requirements	Fulfilled?*
Space heating	Annual heating demand 97 kWh/(m <sup>2</sup> ·a)	15 kWh/(m <sup>2</sup> ·a)	no
	Heating load 39 W/m <sup>2</sup>	10 W/m <sup>2</sup>	no
Space cooling	Overall specific space cooling demand kWh/(m <sup>2</sup> ·a)	-	-
	Cooling load W/m <sup>2</sup>	-	-
Primary Energy	Frequency of overheating (> 25 °C) DHW, space heating and auxiliary electricity Specific primary energy reduction through solar electricity	12.0 %	-
	kWh/(m <sup>2</sup> ·a)	120 kWh/(m <sup>2</sup> ·a)	-
Airtightness	DHW, space heating and auxiliary electricity Pressurization test result n <sub>50</sub>	kWh/(m <sup>2</sup> ·a)	-
	3,0 1/h	kWh/(m <sup>2</sup> ·a)	-
	3,0 1/h	0.6 1/h	no

\* empty field: data missing; -- no requirement

# Diagnosis

## 4. Building energy performance simulation (TRNSYS)





Table 2. Simulation results for comparing simulation tools



Heating energy balance	PHPP (kWh/m <sup>2</sup> a)	TRNSYS (kWh/m <sup>2</sup> a)
Ventilation	17.90	25.70
Transmittance losses	94.70	154.89
Windows	34.60	
Floor/slab basement	13.20	
Roof	11.90	
Ext. wall (ground)	2.30	
Ext. wall (ambient)	32.70	
Solar gains	11.60	62.72
Internal heat gains	13.00	22.23
Convection		12.26
Radiation		9.97
<b>Annual heating demand</b>	<b>88.00</b>	<b>95.64</b>

Table 3. Simulation results for base lining

Heating energy balance	kWh/m <sup>2</sup> a
Ventilation losses (rate 0.3h <sup>-1</sup> )	24.70
Transmittance losses (incl. thermal bridges)	141.15
Infiltrations losses (ACH rate 0.14h <sup>-1</sup> )	25.85
Solar gains	62.72
Internal heat gains (conv.)	12.26
Internal heat gains (rad.)	9.97
<b>Annual heating demand</b>	<b>106.75</b>

# Diagnosis

## 5. Lighting simulation (Dialux)




# Problems, diagnosis and interventions



	Passive solutions	Active solutions	Control
<b>Energy efficiency</b>	Insulation Airtightness decrease	-	Lighting system
<b>Comfort</b>	-	-	Lighting system HVAC system
<b>RES Integration</b>	-	Biomass boilers	-

# Interventions

## 1. RES integration: solar photovoltaic



# Interventions




## 1. RES integration: solar thermal and biomass



# Interventions

## 1. RES integration: solar thermal and biomass



# Interventions




## 2. Energy efficient solutions

- Lighting circuits redistribution
- FCU and ventilation system management




# Interventions

## 2. Energy efficient solutions: Physics laboratory – Redistribution of luminaires



# Interventions



## 2. Energy efficient solutions: Physics laboratory – Control algorithm



# Interventions




## 2. Energy efficient solutions: Physics laboratory – Results



- **Total consumption reduced**
  - **2.2 kW in November 2012**
  - **1.3 kW in November 2013**
  - **Lighting comfort level**
- **Results could be extrapolated to other rooms**

# Interventions



## 2. Energy efficient solutions: Library – Control algorithm



# Interventions



## 2. Energy efficient solutions: Library – Results






- **Average temperature**
  - 21.91°C in October 2012 with a standard deviation 1.86
  - 22.89°C in October 2013 with a standard deviation 1.79
  - Dependency of min and max set-points
- **Comfort level achieved – Reduction of claims**
- **Not significant increment of consumption**
  - In fact, it is sometimes reduced because of automatic control

# Interventions

## 3. Monitoring and control strategies (BMCS)

Zigbee devices installation in combination with the WP4 developed BMS





**Alexandra Troi** [alexandra.troi@eurac.edu](mailto:alexandra.troi@eurac.edu)

**José L. Hernández** [josher@cartif.es](mailto:josher@cartif.es)

**Miguel A. García** [miggar@cartif.es](mailto:miggar@cartif.es)